



29 March 2016

(16-1747)

Page: 1/2

Committee on Technical Barriers to Trade

Original: English

NOTIFICATION 南非 通知—配電盤

The following notification is being circulated in accordance with Article 10.6

1. Notifying Member: <u>SOUTH AFRICA</u> 南非 If applicable, name of local government involved (Article 3.2 and 7.2):
2. Agency responsible: NRCS – National Regulator for Compulsory Specification Name and address (including telephone and fax numbers, email and website addresses, if available) of agency or authority designated to handle comments regarding the notification shall be indicated if different from above: NRCS Private Bag X25 Brooklyn Pretoria South Africa Tel: +27 12482 8702 Email: Theresa.Stoltz@nrcs.org.za
3. Notified under Article 2.9.2 [X], 2.10.1 [], 5.6.2 [], 5.7.1 [], other:
4. Products covered (HS or CCCN where applicable, otherwise national tariff heading. ICS numbers may be provided in addition, where applicable): Low voltage switchgear and controlgear (ICS: 29.130.20) 低電壓配電盤和控制器 (ICS : 29.130.20)
5. Title, number of pages and language(s) of the notified document: VC 8035, Compulsory Specification for earth leakage protection devices (6 pages, in English)
6. Description of content: Earth leakage protection devices, the main contacts of which are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.; rated currents not exceeding 125A and a rated earth leakage not exceeding a tripping current of 30Ma.
7. Objective and rationale, including the nature of urgent problems where applicable: Protection of human health or safety
8. Relevant documents: <ul style="list-style-type: none">• SAN 556-1, Safety standard for circuit breakers• SANS 556-2-1, Earth leakage circuit-breakers• SANS 556-2-2, Earth leakage switches• SANS 556-2-5, Switches incorporating residual current protection• SANS 556-2-3, Low-voltage switchgear: Modular earth leakage devices (without integral current breaking)• SANS 556-2-4, Low-voltage switchgear: Portable earth leakage devices without integral overcurrent protection for household and similar use
9. Proposed date of adoption: Adoption will be after the publication of the final document. Proposed date of entry into force: Entry into force will be after adoption and publication

of the final document.

10. Final date for comments: 60 days from notification

11. Texts available from: National enquiry point [] or address, telephone and fax numbers and email and website addresses, if available, of other body:

NRCS
Private Bag X25
Brooklyn
Pretoria
South Africa
Tel: +27 12482 8702
Email: Theresa.Stoltz@nrcs.org.za